



Page tot. 1		Page 1	
Document No.		201038-5109-E-XJ-0001	
Rev.		01	
Project No: 202038/5109		Kristiansund Havn	
Date: 02.07.18		Landstrøm	
Drawn: KB		Enl./Inj./Jema anlegg	
Date: 02.07.18		Appr: SK	
<p>*Copyright PSW AS. This drawing must not be duplicate or make use of, without permission from PSW Power &amp; Automation AS. WWW.PSW.NO</p>			
1 UTAK 440V 250A 190kVA		1 UTAK 440V 250A 190kVA	
2 UTAK 440V 656A 500kVA 690V 418A 500kVA		2 UTAK 440V 656A 500kVA 690V 418A 500kVA	
1 UTAK 440V 250A 190kVA		1 UTAK 440V 250A 190kVA	
2 UTAK 440V 656A 500kVA 690V 418A 500kVA		2 UTAK 440V 656A 500kVA 690V 418A 500kVA	
Rev.	Description	Sign.	Date:
01	For godkjenning	KB	02.07.2018

1 2 3 4 5 6 7 8

A B C D E F

1.2

CONTAINER 1000kVA

INN SKAP

FREKVENSSOMFORMER

TRANSFORMATOR

UT SKAP

INTERNETT -Bihernet, Cat6A

NETTANALYSATORER -Bihernet, Cat6A

KAI 5

KAI 7

KAI 8

KAI 9

S1 S2 S3 S4 S5 S6

7x2,5mm<sup>2</sup> NØDSTOPP

440V -Q9

690V -Q1

440V -Q2

690V -Q5

440V -Q6

440V -Q10

440V -Q3

440V -Q4

440V -Q7

440V -Q8

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

XXXXXX

TILFØRSEL 400V 50Hz 1250A TN-C-S